



ADDENDUM NO. 1

Date: Tuesday, July 1, 2014

Distribution: Attendees at Mandatory Pre-Bid Conference
Holders of Record Documents, Plan Rooms of Record

Project: Riverbanks Zoo & Garden – Children’s Garden
1201 Seminole Drive
West Columbia, SC 29169
Project Number: B14006-7/15/14

This document comprises Addendum No. 1, forms a part of the Contract Documents and modifies the original bidding documents as noted herein. Acknowledge receipt of this Addendum in the space indicated on the Proposal Form. Failure to do so may subject the Bidder to disqualification.

No other Addenda have been issued to date.

Please note Pre-Bid Conference attendance was Mandatory for General Contractors to be eligible to bid. Only those General Contractors signing the Pre-Bid sign-in sheet are eligible. The list of eligible General Contractors is attached at the end of this document.

Pre-Bid Date/Time: Wednesday, June 25, 2014 – 10:00am
Place: Project Site and Visitor’s Center Board Room

Property Lessee (hereinafter Owner) Richland-Lexington Riverbanks Park District
Riverbanks Zoo and Garden
400 Rivermont Drive
Columbia, South Carolina 29210
Phone: 803-779-8717
Fax: 803-253-6381

Project Address: Riverbanks Zoo & Garden
Project Number: B14006-7/15/14
Parcel: 1201 Seminole Drive
West Campus Entrance: 1300 Botanical Parkway
West Columbia, South Carolina 29169
Tax Map Number: Portion of 004672-01-018

Project Manager: Morgan Grimball, ASLA
Grimball Cotterill & Associates
600 Beltline Boulevard
Columbia, SC 29205
Phone: 803-738-9525
Email: morgan@grimballcotterill.com

Bid Opening:

The Bid Opening date for this project remains as published:

Bid Date, Time: Tuesday, July 15, 2014 at 2:00pm

Location: 400 Rivermont Drive, Second Floor Conference Room, Columbia, SC 29210

Hand Deliver/Mail or Courier Bids To:

**Riverbanks Zoo & Garden
Procurement Services
Attn.: Ms. Jo Marie Brown, CPPB
400 Rivermont Drive
Columbia, SC 29210**

Bidders are responsible for having their Bid at the designated place for receiving bids no later than the time set for the Bid opening. Once the Bid has been declared closed (based on current cell phone time), all late Bids, including Bids improperly delivered, shall be rejected as being non-responsive.

All late Bids or Bids improperly delivered will be rejected as non-responsive.

Bids sent by a courier or delivery service (UPS, Airborne, Federal Express, etc.) must be addressed to the attention of **Ms. Jo Marie Brown, CPPB, Riverbanks Zoo & Garden, Procurement Services, 400 Rivermont Drive, Columbia, SC 29210** and to be received with adequate time prior to the bid opening time. Bids must be in the possession of Ms. Brown at or prior to 2:00 PM on Tuesday, July 15, 2014 to be considered. It is recommended that all Bidders attending the Bid Opening should plan to arrive early to allow for possible train delays.

It is the responsibility of the Bidder to ensure that the Bid is at the designated address at or before Bid time. The name of the Bidding firm on the 00300 Bid Form should match the name on the company firm's Contractor License.

There are many certifications that the Bidder makes by Submitting a Bid, please be aware of the responsibilities of the following certifications:

Bid Security is required in the amount of 5% of the total Bid amount; South Carolina Office of the State Engineer rules apply to this project for surety ratings.

There is one (1) Alternate – Tram Stop Turnaround.

The Tram Stop Turnaround is an add alternate and that work, if accepted by RBZ, will be required to be completed on or before January 1, 2015.

Critical Date Review

Mandatory Pre-Bid Conference	Wednesday, June 25, 2014	10:00 am
Final Questions/Substitution Requests from Bidders	Thursday, July 3, 2014	No Later Than 5:30pm
Final Addendum	Thursday, July 10, 2014	No Later Than 2:00pm (120 hours prior to Bid Opening)
Bidding	Tuesday, July 15, 2014	33 Day Bid Period
Preliminary Recommendation	Thursday, July 17, 2014	Based on Bids/Budget Only
Owner Board Approval	Thursday, July 17, 2014	3 rd Thursday of the Month, may move to July 31 st .
Sub-Contractor Review & Final Recommendation	Thursday, July 24, 2014	
Anticipated Award	Thursday, July 24, 2014	
Anticipated Contract	Thursday, July 31, 2014	
Anticipated Mobilization	Monday, August 11, 2014	Construction Start

No partial drawing sets will be issued. Items appearing on one drawing or in the specifications are as though they appear on all project documents. Bids prepared from partial sets will not be a basis of change for change requests to the Owner, if any.

Substitutions: Materials and products listed in the Bid Documents establish a standard of required function, dimension, appearance and quality to be met by a proposed substitution. Requests for substitutions must be submitted in writing utilizing a completed 01631-A Product Substitutions Request Form as provided in the project manual to the Landscape Architect no less than ten (10) days prior to the bid date. Proof of equality of substitutions is the responsibility of the proposer. The Landscape Architect's decision to approve or disapprove of the requested substitutions shall be final.

Questions/Clarifications: Only the written word as contained in the Bid Documents and any addenda that may be issued are binding. It is the bidders' responsibility to read and review all of the Bid Documents, including addenda. All questions or requests for clarification must be submitted in writing to the Landscape Architect no less than ten (10) days prior to the bid date. All responses will be made in the form of Addenda to the bid documents.

Addenda: The Final Addendum will be published no later than 2:00pm on Thursday, July 10, 2014, 120 hours prior to Bid Opening. All Addendums will be posted on the Riverbanks Zoo and Garden website at: <http://www.riverbanks.org/procurement> and will be available from all listed Plan Rooms and TPM at: www.tpm-columbia.com. Addenda are e-mailed to known Bidders holding plans, attendees at the Mandatory Pre-Bid Conference and also to the Plan Rooms of Record. Addenda may also be faxed or mailed if e-mail is not available. It is the bidder's responsibility to determine, prior to submitting a Bid, that all Addenda issued have been received and to so indicate on their 00300 Bid Form.

Specification Section 01100 – Summary of Work. Project Summary and Geotechnical/Testing was reviewed.

The General Contractor shall be responsible for providing a comprehensive Staging Plan.

See Allowances, Specification Section 01210 and Alternates, Specification Section 01230.

The General Contractor will have use of the Site for construction operations as outlined in these documents. It is imperative that all Riverbanks Botanical Garden and Visitor Center facilities be kept accessible and in operation during the course of construction. The GC shall be solely responsible for maintaining the security, safety and staging as necessary for project conditions.

Quality Assurance Testing and Special Inspections will be provided by the General Contractor.

Liquidated Damages are \$500 per calendar day for failure to achieve Substantial Completion within the Contract time limits.

Protocol: The General Contractor must coordinate all information through the Landscape Architect unless otherwise authorized to keep resolution to issues and information processing efficient. Protocol for all issues is through the General Contractor, and the General Contractor to the Landscape Architect. The Landscape Architect may elect to authorize communications between subcontractors and the project Engineers, in which case, a phone log must be kept and provided to the Architect. No changes are authorized without the Owner's or the Architect's prior approval.

The General Contractor is responsible for purchasing Builders Risk Insurance for this project.

Constraints of the project site, existing conditions and facility accessibility requirements were discussed.

Trades/Subcontractors: List all Trades/Subcontractors indicated on the 00300 Bid Form, some of these require qualifications as listed in the Exterior Carpentry and Cultured Stone Veneer Specification sections. Those qualifications will be checked prior to award. If more than one firm is to be used for a particular trade, list both by using the word “and”.

Sitework / Hardscape
Irrigation
Cultured Stone Work

Building Contractor
Treehouse Carpentry

The successful Contractor shall be required to work in conjunction with separate design/build contracts as selected by the Owner. The Design-Build Contractor, Cost of Wisconsin and their local sub-contractor, W.P. Law, Inc., will provide components and installation for the Rabbit Hole Entry, the Rabbit Warren, the Water Features, the Dino Dig, the Climbing & Slides, the Amphitheaters and the Pump House. The Design-Build Contractor documents are included in, and are made a part of, the Project Documents for Contractor reference and coordination of the Work.

Owner-Furnished Items and Separate Contracts: Where the Owner will provide certain construction, equipment, furnishings and decor items for the Project, the General Contractor shall be responsible for overall coordination, scheduling and support as necessary to accommodate the Work. The Owner has employed a Specialty Design-Build Contractor for the Work; see Supplementary Conditions, Article 6.

Project Time, Staging and Schedule: The project shall be Substantially Complete within 365 calendar days from the Contractor's Notice to Proceed. Final Completion will be 30 days thereafter. The contract time of 12 months versus 15 months was discussed. The Contract time shall remain 12 months as published.

Use Of Premises: Contractor shall have full use of the premises for construction operations within the project limits and as delineated on the documents except as noted otherwise therein. The Contractor is advised that the areas of the site adjacent to the project limits are occupied by the Public and Zoo employees and the Contractor shall provide protectives as necessary to protect adjacent areas from construction activities. The Contractor shall be responsible for all protectives. Security and protective measures shall be submitted to the Landscape Architect and approved prior to commencing construction. See sheet sd1.1 and Section 01500 Temporary Facilities. Refer to drawing sd1.1 for location of Contractor's staging area to be coordinated with and agreed upon by Zoo personnel prior to construction commencement. The Contractor may use existing service roads contained immediately adjacent to and within the project boundary but must not fully block these roads to accommodate Owner operations during construction. Further, the West Campus provides venues for the Visitor's Center events and unobstructed access to their service area during and after normal business hours is required. There may be an opportunity to install a secondary temporary field office in the vicinity of the Education Center with permission from the Owner.

Partial Owner Occupancy: The Owner reserves the right to request partial occupancy to place and install landscaping, equipment or other items in partially completed areas prior to Substantial Completion provided such occupancy does not interfere with the Contractor's completion of the Work. Placing of these items and partial occupancy shall not constitute acceptance of the total Work and is the responsibility of the Contractor to coordinate. This item includes, but is not limited to, top soil and landscaping that will be provided by the Owner. The Contractor shall endeavor to provide finished grade areas as they become available for the Owner to place topsoil and landscaping. Coordinate sequencing requirements with the Owner.

Zoning, Permitting and Contractor Coordination: Refer to Section 01115 Permitting and Utilities. Permitting will be accomplished by the Landscape Architect on behalf of the Owner. The Contractor shall be responsible for coordination and procurement of all permits affiliated with the construction of the project. The Recreational Water Permit is in process through SC DHEC.

Following the Pre-Bid Conference, all attendees were invited to tour the proposed site.

Addendum Items

Question: Is the General Contractor responsible for costs involved with the trench testing required on the work performed by the Design-Build Contractor?

Answer: No, the Design-Build Contractor will be responsible for the compaction of their own trenches and verification therein.

Question: For the sod areas, is the General Contractor responsible for both the sod installation and the topsoil required beneath it?

Answer: No, the General Contractor will place the sod after the Zoo installs the topsoil. The process must be coordinated by the Contractor.

Refer to Section 00300, Bid Form.

Please add page 6 to the bid form as attached to the end of this document.

Refer to Specification Section 02735 Aggregate Base Course, Tolerances – Compaction.

Modify as follows; GABC in vehicular traffic areas shall be compacted to a minimum 95% modified proctor ASTM D-1557. GABC under pedestrian pathways (2" compacted thickness) to be roller compacted prior to placement of sidewalks.

Refer to Specification Section 02300-5, paragraph "Rock Excavation and Ripping Criteria".

Delete the Civil definitions for Mass, Limited and Trench Excavation and utilize the Geotechnical definitions as stated on page 11 of the Geotechnical Report included in the Project Manual as the basis of contract.

Refer to Specification Section 02230-2, third paragraph "Salvable Improvements".

As stated, the Owner will find a location for salvaged boulders. A location will be determined at the Pre-Construction conference.

Refer to the Civil Documents.

There may be drain basin inlet structures that cannot meet the minimum manufacturer angle requirements for multiple incoming pipes. These inlets shall be precast concrete or built in place with concrete brick as necessary.

Refer to Sheet C2.0.

The Graphics Legend on this sheet indicates the walls affiliated with the playhouses are Segmental Block walls. To clarify, these walls are stone walls as indicated as Item 8 in the Key Notes. Please revise as necessary.


Refer to Sheet L2.1.

The Dinobonz Bench photo did not print properly on the plans, the photo is shown below:



Refer to Sheet L5.1.

The Backyard Cottage photo did not print properly on the plans, the photo is shown below:



Refer to the Pump House Floor Plan on Sheet a1.1a.

No foundations were indicated in the Structural documents for the Pump House. Add two (2) attached sketches Addendum 1.0 (S1 of 2) and Addendum 1.0 (S2 of 2). Sketches are attached at the end of this Addendum.

Refer to the Treehouse Sheet tha1.3.

Note regarding 2" aged hardwood mulch, "After wall work is complete, remove all debris, branches, spoils etc. and apply 2" of aged hardwood mulch to treehouse site to boundary shown."

Revise note to read: "After hand clearing all small scrub, apply 4" of aged hardwood mulch to treehouse site to boundary shown for additional root protection in treehouse area. After all work is complete, remove all debris branches spoils etc."

Refer to Specification Section 16720, Paragraph one.

Delete the following sentence: "Equipment shall be by Notifier-Honeywell, Gamewell-FCI, Edwards Signaling, Simplex-Grinnell or approved equal". Replace with the following: "**Equipment shall be by SimplexGrinnell**". Please note that Riverbanks has just entered a master campus agreement with SimplexGrinnell.

Refer to Sheet eS02.

Sheet being reissued with Addendum items. Items are clouded. Drawing is attached at the end of this Addendum.

Refer to Sheet e301.

Custodial 110b: Provide S-2 (See Safety Switch Schedule) disconnect switch adjacent to EWH-1 for 6.0KW Electric Water Heater. Provide 3 #10, #10 GRD, 3/4" conduit to 30A/3P circuit breaker in panelboard D, spaces 37, 39, 41. Provide 120V for recirculation pump from nearest general purpose circuit – connect complete. See plumbing drawings for exact locations.

Cad Site Drawings Available:

For Contractors who prefer AutoCAD for site take-offs, a disclaimer and indemnification is attached at the end of this Addendum. Fill in and sign the form and send by email to Morgan Grimball at morgan@grimballcotterill.com if you would like the AutoCAD file.

Approved Equals:

(All manufacturers listed in the Specifications and/or drawings and those listed herein are approved subject to compliance with Project requirements, specifications and compatibility. Products not meeting the specified requirements remain subject to rejection).

Requests for substitution have been considered if received no less than ten (10) days prior to Bid in the format and with the information specified. Those requests that are approved are included herein.

Civil None at this time

Landscape None at this time

Architectural

Refer to Specification Section 03300, Vapor Barriers: **Barrier-Bac VB250 is an approved equal.**

Refer to Specification Section 10162, Toilet Partitions: **Guardian Partitions by Alan Lewis, Inc. Phenolic Partitions are an approved equal.**

Mechanical None at this time

Electrical None at this time

Pre-Bid Conference Attendees

Riverbanks Zoo & Garden – Children’s Garden

Wednesday, June 25, 2014, 10:00 am, at Project Site, 1201 Seminole Drive

Project #B14006-7/15/14

Owner

Mr. Satch Krantz, CEO
Riverbanks Zoo & Garden
400 Rivermont Drive
Columbia, SC 29210
Phone: (803) 779-8717
Fax: (803)

Ms. Jo Marie Brown, Procurement Manager
Riverbanks Zoo & Garden
400 Rivermont Drive
Columbia, SC 29210
Phone: (803) 779-8717 or (803) 602-0831
Fax: (803) 771-8722

Mr. Dave Sharpe
Riverbanks Zoo & Garden
400 Rivermont Drive
Columbia, SC 29210
Phone: (803) 779-8717 or (803) 439-6545
Fax: (803)

Landscape / Building Architects

Mr. Morgan Grimball
Grimball Cotterill & Associates
Landscape Architect
600 Beltline Blvd.
Columbia, SC 29205
Phone: (803) 738-9525
Fax: (803) 782-3916
Email: morgan@grimballcotterill.com

Mr. Joel McCreary, Architect
McCreary/Snow Architects, PA
Architect
P.O. Box 11143
Columbia, SC 29211
Phone: (803) 771-6267
Fax: (803) 771-6264
Email: jm@msarch.net

Ms. Laurel Gibson, Construction Administration
McCreary/Snow Architects, PA
Architect
P.O. Box 11143
Columbia, SC 29211
Phone: (803) 771-6267
Fax: (803) 771-6264
Email: lgibson@msarch.net

Design-Build Consultants

Mr. Glenn Clonts
W. P. Law, Inc.
303 Riverchase Way
Lexington, SC 29072
Phone: (803) 461-0599
Fax: (803) 461-0570
Email: glenn@wplawinc.com

Mr. Mike Clonts
W. P. Law, Inc.
303 Riverchase Way
Lexington, SC 29072
Phone: (803) 461-0599
Fax: (803) 461-0570
Email: mclonts@wplawinc.com

General Contractors

Mr. Mike Sweatt, Senior Estimator
AOS Specialty Contractors, Inc.
General Contractor
1224 Two Notch Road
Lexington, SC 29073
Phone: (803) 798-6831
Fax: (803) 798-6696
Email: mike@aossc.org

Ms. Jane Plante
AOS Specialty Contractors, Inc.
General Contractor
1224 Two Notch Road
Lexington, SC 29073
Phone: (803) 798-6831
Fax: (803) 798-6696
Email: jane@aossc.org

Mr. Scott Jordan
Buchanan Construction Service
General Contractor
(2800 William Tuller Dr., 29205)
P. O. Box 6782
Columbia, SC 29260
Phone: (803) 695-2123
Fax: (803) 695-2124
Email:
dbuchanan@buchananconstructionservices.com

Mr. Bobby Benton
Cherokee, Inc.
General Contractor
P. O. Box 90448, 6928 Cheval St.
Columbia, SC 29290
Phone: (803) 730-4411 (c) or (803) 776-4870 (o)
Fax: (803) 776-5507
Email: bbenton1@yahoo.com

Mr. Lee Bedenbaugh
Core Construction
General Contractor
P. O. Box 2566, 1315 Platt Springs Road
West Columbia, SC 29171
Phone: (803) 791-8788
Fax: (803) 791-0388
Email: lee@coreconstructionsc.com

No Name Given
FBi Construction
General Contractor
P. O. Box 3407
Florence, SC 29502
Phone: (843) 665-0405
Fax: (843) 665-7715
Email: charlie.white@fbiconstruction.com

Mr. Bryan Rembert
IPW Construction Group, LLC
General Contractor
7623 Dorchester Road
North Charleston, SC 29418
Phone: (803) 460-0447
Fax: (843) 308-6650
Email: brembert@ipwco.com

Mr. Mike Lever
L-J, Inc.
General Contractor
200 Stoneridge Dr., Ste. 405
Columbia, SC 29210
Phone: (803) 929-1181
Fax: (803) 929-7625
Email: mlever@l-jinc.com

Mr. Frank Sprankle
Lindler Construction
General Contractor
532 South Edisto
Columbia, SC 29201
Phone: (803) 252-9948
Fax: (803) 779-3609
Email: hosl@bellsouth.net

Mr. Mike Rozbitsky
MAR Construction Co.
General Contractor
141 Riverchase Way
Lexington, SC 29072
Phone: (803) 796-8960, Ext. 305
Fax: (803) 796-4400
Email: miker@marconstruction.com

Ms. Jessica Branson-Turner
North Lake Construction Co., Inc.
General Contractor
5102 Augusta Road
Lexington, SC 29072
Phone: (803) 359-9050
Fax: (803) 359-8898
Email: royce@northlakeconstruction.com

Mr. Paul Miller, Senior Project Manager
Rodgers Builders
General Contractor
(P.O. Box 18446, 28218)
5701 North Sharon Amity Road
Charlotte, NC 28215
Phone: (704) 537-6044
Fax: (704) 535-0055
Email: pmiller@roddersbuilders.com

Mr. Frank Ayers
Solid Structures, LLC
General Contractor
2548 Morningside Drive
West Columbia, SC 29169
Phone: (803) 926-0298
Fax: (803) 926-0299
Email: jnoah@solidstructures.info

Ms. Dot McConnell
Triangle Construction Co., Inc.
General Contractor
(2624 Laurens Rd., 29607)
P. O. Box 6266
Greenville, SC 29606
Phone: (864) 288-5500
Fax: (864) 458-8800
Email: mpraytor@triangleconstruction.com

Mr. Greg Tyler, Vice President
Tyler Construction Group
General Contractor
433 Rabon Road, P. O. Box 25037
Columbia, SC 29224
Phone: (803) 865-1404
Fax: (803) 865-1415
Email: gtyler@tyler-construction.com

Subcontractors / Suppliers

Mr. Ron Mahaley
Capital Concrete Co.
Ready Mix
1059 Bonhomme Richard Rd.
Lexington, SC 29072
Phone: (803) 600-7840 (c) or (803) 808-0825 (o)
Fax: (803) 808-0984
Email: rmahaley@capitalconcreteco.com

Mr. H. Guy Gantt
Pioneer Tree Service
Arborist
P. O. Box 1726
Columbia, SC 29202
Phone: (803) 794-8253
Fax: (803) 794-0540
Email: None Available

Mr. Tommy McCants
SimplexGrinnell
Fire Alarm
3243 Sunset Blvd.
W. Columbia, SC 29169
Phone: (803) 476-0033 (o) or (803) 391-0095 (c)
Fax: (803) 476-0039
Email: tmccants@simplexgrinnell.com

Mr. Chris Stuyck, Owner
Stuyck Company
Welding Fabricator
1851 Shop Road
Columbia, SC 29201
Phone: (803) 376-8964
Fax: (803) 376-8966
Email: chris@stuyckcompany.com

Plan Rooms / Owner Procurement

TPM Columbia at:
www.tpm-columbia.com
Carolinas AGC at:
www.cagc.org or www.isqft.com
HCACarolinas at:
www.hcacarolinas.com or www.isqft.com
Reed Construction Data at:
www.reedconstructiondata.com
Riverbanks Zoo & Garden Procurement at:
www.riverbanks.org/procurement

Other Plan Holders of Record

China Construction
700 Saturn Parkway
Columbia, SC 29212
Phone: (803) 771-2777

Contract Construction, Inc.
P. O. Box 269
Ballentine, SC 29002
Phone: (803) 781-7058

Richardson Construction
6806 Monticello Road
Columbia, SC 29203
Phone: (803) 786-9741

Attachments: 00300 Bid Form, page 6, rev 070114
Addendum 1.0 (S1 of 2)
Addendum 1.0 (S2 of 2)
Drawing Sheet eS02
AutoCAD Request & Release Form

End of Addendum No. 1

Please provide the following information affiliated with your bid. This is for information only and the amounts provided are non-binding:

Of the bid amount listed please list the following monetary break-outs:


Building Construction – Education Center: \$ _____

Treehouse Construction: \$ _____

Sitework (excluding Tram Stop Turn-Around: \$ _____

Revised End of Section 00300
Addendum 1, July 1, 2014

6" thick 3000 psi concrete slab-on-grade
w/ #4 @ 12" o.c. and 4" sand below. See
specifications for vapor barrier.



Foundation Plan


Riverbanks Zoo and Garden
Children's Garden

Addendum 1.0 (S1 of 2)
Pump House Foundation

Date: June 30, 2014

Job #: C&A Job #: 391761-13





Section 1

Riverbanks Zoo and Garden
Children's Garden

Addendum 1.0 (S2 of 2)
Pump House Foundation

Date: June 30, 2014

Job #: C&A Job #: 391761-13





**ELECTRONIC DOCUMENT
TRANSFER REQUEST**

R.B. Todd Consulting Engineers
7436 Broad River Road, Suite 212
Irmo, SC 29063
Telephone: 803-781-3141, Fax: 803-781-3142

RIVERBANKS ZOO & GARDEN – CHILDREN’S GARDEN (B14006-7/15/14)

Date: _____
Company requesting files: _____
Person requesting files: _____
Description of files: _____

-
1. The requested electronic file(s) (the “Files”) remain the property of R.B. Todd Consulting Engineers.
 2. No warranties or guarantees are made that the Files represent or reflect the complete scope of work.
 3. Company receiving the Files and users thereof shall indemnify and hold R.B. Todd Consulting Engineers harmless from any claims or damages arising from the use of the Files in the execution of the work.
 4. In the event that drawing files transferred contain R.B. Todd Consulting Engineers title block, permits or professional seals, the Files shall be immediately returned to R.B. Todd & Associates and all copies thereof destroyed.
 5. The use of Files to alter or revise the scope of work is not permitted unless authorized by change orders.
 6. No use shall be made of the Files for any purpose other than that for which they were originally intended without the express written consent of R.B. Todd Consulting Engineers.
 7. No retransmission of the Files in any form to any third party is permitted unless authorized in writing by R.B. Todd Consulting Engineers.

Having read and understood the above, the undersigned agrees to be bound by the terms thereof.

Signature of Company’s Authorized Representative

Date

The above requested files will only be released upon receipt by R.B. Todd Consulting Engineers, of an original of this form signed by a duly authorized representative of the company requesting the files. R.B. Todd Consulting Engineers reserves the right to deny any request for copies of electronic files.